


## Installation Instructions LINIER<sup>®</sup>SWING-OUT WALL MOUNT CABINETS

#### **Part Numbers:**

#### Glass Door

6U - 3130-3-001-06 9U - 3130-3-001-09 12U - 3130-3-001-12 15U - 3130-3-001-15 18U - 3130-3-001-18 22U - 3130-3-001-22 Solid Door 6U - 3131-3-001-06 9U - 3131-3-001-09 12U - 3131-3-001-12 15U - 3131-3-001-15 18U - 3131-3-001-18 22U - 3131-3-001-22 Vented Door

6U - 3132-3-001-06 9U - 3132-3-001-09 12U - 3132-3-001-12 15U - 3132-3-001-15 18U - 3132-3-001-18 22U - 3132-3-001-22




# PLEASE READ INSTRUCTIONS BEFORE MOUNTING


IT IS CRITICAL THAT THE CABINET BE INSTALLED CORRECTLY TO MAINTAIN SAFETY AND WEIGHT CAPACITY


Information Support Concepts 2384 Highway 287 N. Suite 208 Mansfield, TX 76063-9207

800-458-6255 U.S. Only Fax (817) 842-9099 Local (817) 842-9090

www.serverrackoptions.com








## **Removing Knock Outs**

1) Insert a flat head screwdriver into the small opening at the edge of the knock out.

2) Pry upwards and twist until insert breaks free.



## Adjusting the Rail Depth

1) Unscrew the rail from the rail support. Move the rail forwards or backwards to desired location. Insert screw and secure.

